

## Baghouse Nuances: What to do when a Baghouse Source Test goes Rogue

MECC Conference ♦ April 11, 2018

Janet Scheier, Managing Consultant

# Baghouse Basics

- > Design phase
- > Air system
- > Bags
- > Maintenance




# Design phase

- > Most critical parameters are flow rate and particulate loading
  - ❖ Higher efficiencies gained with lower velocity of air through filter
  - ❖ Must balance needs: lower velocity means more filterable area (aka, bigger baghouse, more capital cost)
- > Carefully choose materials of construction
  - ❖ Look at chemical profile of exhaust stream
  - ❖ Look at climate

# Air system

## > Components of Air System

- ❖ Fan
- ❖ Compressed Air System
  - ♦ Regulators
  - ♦ Dryers
  - ♦ Receivers
- ❖ Valve Actuators
- ❖ Pressure Gauges





# Bags (1 of 2)

- > Understand your bag type - conventional vs. membrane
  - ❖ Does it need a seasoning period to achieve peak performance?
- > Must be designed for chemical profile of exhaust stream
  - ❖ Exhaust temperature and moisture
  - ❖ F and Cl and SOx



# Bags (2 of 2)

- > Bags are a bit custom designed - be careful of using different vendor
- > Watch how it fits in cage/tube sheet
  - ❖ Snap band should fit snug against tube sheet
  - ❖ Bag should be tight to the cage, not loose



# Maintenance

- > Stop, Look, Listen
- > Watch for buildup in the hopper of baghouse
- > Check baghouse before test
  - ❖ Physically check - turn fan off and open door on clean side
    - ◆ If PM on tube sheet, clean it
    - ◆ Change bags if needed
    - ◆ Look for anything indicating a leak
  - ❖ Check performance of bag leak detection system and pressure gauges
  - ❖ Trust but verify



# When you get a rogue test result: Case Study #1



- > Plant personnel says they've checked everything and they are "good to go"
- > Fail stack test
- > Root Cause - Caked-on PM on the clean side of the tube sheet, was never checked before conducting the stack test



# When you get a rogue test result: Case Study #2

- > Plant personnel says they've checked everything and they are "good to go"
- > Fail stack test
- > Further investigation reveals simple cause
  - ❖ Tube sheet had buildup of PM on clean side
  - ❖ 18 broken bags found
  - ❖ Bag Leak Detector had been disconnected from PLC, showing no indication of failures

# When you get a rogue test result: Case Study #3



- > Baghouse seems to be working fine
- > Stack test runs results in gradually higher emission rates at 1.3x, 2.1x, and 3.6x the limit, respectively; pressure drop steady
- > Facility decides to re-test with new bags and other maintenance refinements
  - ❖ Same results - emission rates up to 5xs limit
  - ❖ Pressure drop still steady

# When you get a rogue test result:

## Case Study #3 (2 of 5)

- > At end of stack test, looked inside and found that buildup from bottom of baghouse reached bags and pulled them down
  - ❖ Ordered weighted tip valve to ensure timely release of buildup
  - ❖ Also considered auger system
- > Bigger issue: Realized that some of the pulse bar holes had worn into a large slot caused larger than needed air pressure and worn seals on the bags

# When you get a rogue test result: Case Study #3 (3 of 5)





# When you get a rogue test result: Case Study #3 (4 of 5)

Eventual culprit was a faulty air regulator on the pulse system. In addition, moisture had also infiltrated the system due to a temporary compressor that had been operating without a dryer.



# Final thoughts

- > Prior to the test - Trust but Verify!
- > Diagnose before you prescribe
- > Know your process
- > Tools to assist
  - ❖ Monitors that determine if disturbances occur during pulsing
  - ❖ Bag Leak Detectors in every compartment



---

# Questions/Comments/ Experiences

